

Bellaterra, 30<sup>th</sup> November, 2020  
File number: **20/ 23467 - 2168**  
Applicant: BODY ONE  
47 Rue Cartier Bresson  
93500 Pantin  
France

Date of material delivery: 28<sup>th</sup> October, 2020  
Date of testing: 29<sup>th</sup> October to 24<sup>h</sup> November, 2020

## TEST REPORT

### corresponding to *Medical face masks*

#### ISSUE REQUESTED

Tests indicated in the application form, according to prescriptions of standard cited below:

- EN 14683: 2019 + AC: 2019 "Medical face masks. Requirements and tests methods"

This document has <b>7</b> pages of which <b>0</b> is annex, this being page number 1.
--

File number: **20/ 23467 - 2168**

Pg. number: **2 of 7**


**SAMPLES** (information reported by the Applicant)

**Sampling**

Date: October 2020

Responsible: BODY ONE

**Sample description**

REFERENCE	DESCRIPTION TISSUE / LAYERS	RECEIVED FORMAT	Identification A+
<b>BODY ONE</b>	3 layers	Face mask	20/ 2168
			
<b>PACKAGING</b>	Box of 50 units, with bags of 10 units inside		

**SCHEDULE OF THE TESTS** (only the requested tests are indicated)

Standard EN 14683	Sample ref. <b>BODY ONE</b>	Number of samples used in tests
Clause 5.2.2 & Annex B: <sup>[1]</sup> Bacterial filtration efficiency (BFE)	X	5
Clause. 5.2.3 & Annex C: Breathability (Differential pressure)	X	5
Clause. 5.2.4 & standard ISO 22609: <sup>[1]</sup> Splash resistance	X	32
Clause 5.2.5 & Annex D: <sup>[2]</sup> Microbial cleanliness (bioburden)	X	5

Note.- Test carried out in a collaborating centre: <sup>[1]</sup> AQUIMISA; <sup>[2]</sup> EURECAT

### **REQUIRED REQUIREMENTS**

According to table 1 of the standard EN 14683, the classification of medical face masks is determined based on the limits established for each of the tests.

Test	Classification	Type I	Type II	Type IIR
BFE	(%)	$\geq 95$	$\geq 98$	$\geq 98$
Differential pressure	Pa/cm <sup>2</sup>	$< 40$	$< 40$	$< 60$
Splash resistance	kPa	NR	NR	$\geq 16$
Microbial cleanliness	CFU/g	$\leq 30$	$\leq 30$	$\leq 30$

NR: not required

### **TEST RESULTS**

The result obtained in the samples tested is indicated below, as the average value of the partial values in each of the tests.

<b>Standard EN 14683</b>			Sample ref. <b>BODY ONE</b>
Clause 5.2.2	Bacterial filtration efficiency (BFE)	[%]	<b>&gt;99.9</b>
Clause 5.2.3	Breathability (Differential pressure)	[Pa/cm <sup>2</sup> ]	<b>59.4</b>
Clause 5.2.4	Splash resistance	[to 17 kPa]	<b>OK</b>
Clause 5.2.5	Microbial cleanliness (bioburden)	[CFU/g]	<b>5.8</b>

### Primary results

#### A) Bacterial filtration efficiency (BFE)

	Sample nm.1	Sample nm.2	Sample nm.3	Sample nm.4	Sample nm.5
Sample ref.:	BFE [%]				
<b>BODY ONE</b>	>99.9	>99.9	>99.9	>99.9	>99.9

#### B) Breathability (Differential pressure)

Sample ref.:		Sample nm.1	Sample nm.2	Sample nm.3	Sample nm.4	Sample nm.5
<b>BODY ONE</b>		[Pa]				
Breathability	(1)	334	317	252	276	323
	(2)	302	295	289	329	262
	(3)	268	264	268	334	302
	(4)	284	287	234	255	286
	(5)	277	301	348	293	301
	MEDIA	293	293	278	297	295
$\Delta P$	[Pa/cm <sup>2</sup> ]	59.8	59.8	56.8	60.7	60.2

#### C) Splash resistance

Sample nm.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
PASS	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
NO PASS																

Sample nm.	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32
PASS	X	X	X	X	X	X	X	X	X	X		X	X	X	X	X
NO PASS											X					

Remark.- Result non conform if more than 3 samples fail

## D) Microbial cleanliness (bioburden)

Sample ref.: <b>BODY ONE</b>	<b>Position inside packaging</b>	<b>Sample weight [g]</b>	<b>TSA plate [CFU]</b>	<b>SDA plate [CFU]</b>	<b>Total [CFU]</b>	<b>Total by weight [CFU/g]</b>
Sample nm.1	Top	3.17	16	5	21	6.62
Sample nm.2	Randomly	3.24	10	1	11	3.40
Sample nm.3		3.13	10	3	13	4.15
Sample nm.4		3.16	16	4	20	6.33
Sample nm.5	Bottom	3.17	24	3	27	8.52

**Test conditions**

## A) Bacterial filtration efficiency (BFE)

Number of samples	5 units
Dimensions of test sample	10 cm x 10 cm
Size of the area under test	50 cm <sup>2</sup>
Position of test sample	Internal face towards the inoculating spray
Environmental test conditions	T= 21 °C / RH= 80 %
Test control unit	Andersen Cascade Impactor of 6-steps
Air flow	28.3 l/min
Test microorganism	Staphylococcus aureus ATTC6538
Bacterial suspension (inoculum)	1.7 x 10 <sup>3</sup> y 3 x 10 <sup>3</sup> CFU/ml
Incubation conditions	20-52 h a (37 ± 2)°C
Test duration	2 min / test sample

### B) Breathability (Differential pressure)

Number of samples	5 units
Number of repetitions per sample	5
Size of the area under test	Ø 25 mm
Environmental temperature	(22 ± 2)° C
Test control unit	Mass flow meter
Air flow	(8 ± 0.2) ℓ/min

### C) Splash resistance

Number of samples	32 units
Dimensions of test sample	Ø 5 cm
Size of the area under test	19.6 cm <sup>2</sup>
Test method	ISO 22609: 2004
Environmental temperature	21 °C
Test parameter (pressure)	127.5 mmHg (17 kPa)
Synthetic blood volume	2.0 ml

### D) Microbial cleanliness (bioburden)

Number of samples	5 units
Test method	EN ISO 11737-1:2018
Extraction liquid	Peptone, NaCl and Tween 20, dissolved in Milli-Q water
Soluciones	TSA: Tryptic Soy Agar, pH 7.3±0.2 SDA: Sabouraud Dextrose Chloramphenicol Agar, 5.6±0.2
Sterile Cellulose Nitrate Membrane Filter	Size grid 0.45µm
Incubation	TSA plate: 3 days to 30°C SDA plate: 7 days to 25°C

**GENERAL REMARKS**

Based on the results obtained from the requested tests and the limits indicated in Table 1 of the EN 14683 standard (see page 4 of this report), the resulting classification of the samples tested could be: "type IIR".

*Laboratory Technician: Marc Parera*

Signed by



Technical Manager

Product Conformity B.U.

LGAI Technological Center, S.A.(APPLUS)

This document may only be reproduced in full.

Only reports with an original signature on their respective certified copies will be legally valid.

The results refer exclusively to the sample, product or materials received in the laboratory, as indicated in the section pertaining to the description of the material received, and tested in the conditions described in this test report.

LGAI Technological Center, S.A. is not responsible for the documentation and / or information provided by the manufacturer.

**Applus+** guarantees that this task has been carried out in compliance with the requirements of our Quality and Sustainability System, and furthermore, that the contractual terms and legal regulations have been complied with.

In the framework of our improvement program, we would appreciate any comments you may deem appropriate. These should be addressed to the manager who signs this document, or to the Quality Director of Applus+, at the following address:  
[satisfaccion.cliente@applus.com](mailto:satisfaccion.cliente@applus.com)